

Test Report No. **SC / 105612**

SHORT-CIRCUIT LABORATORY

Page 1 of 21

Client : VAN WYK'S ELECTRICAL (VWE), 141 Station Road, Brakpan, South Africa
Manufacturer : VAN WYK'S ELECTRICAL (VWE), 141 Station Road, Brakpan, South Africa
(subject to joint venture agreement as appended to this test report)
Apparatus : Three-phase low-voltage switchgear and controlgear ASSEMBLY
Designation : VWS3000 **Serial No.** : -

Ratings assigned by the manufacturer:

Operational voltage: Up to 1000 V A.C
Rated short-circuit withstand current $I_{cw} = 50 \text{ kA}$ for 1s, $I_{pk} = 105 \text{ kA}$
Rated frequency: 50 Hz
Other characteristics listed on page 2

The tests have been carried out strictly in accordance with:

IEC 61439-2:2009 Ed. 1 / SANS 61439-2:2009 Ed. 1 and IEC 61439-1:2009 Ed. 1 / SANS 61439-1:2009 Ed. 1
Low-voltage switchgear and controlgear assemblies
Part 1: General rules and Part 2: Power switchgear and controlgear assemblies

Date of test(s): Period including 02 August 2010 to 03 September 2010

THE APPARATUS HAS COMPLIED WITH THE FOLLOWING CLAUSES OF IEC / SANS 61439 SERIES

Part 2:Sub-clause 8.101	- Internal separation of ASSEMBLIES by barriers or partitions	
	- Incomer: FORM 1	- Outgoing functional units
		FORM 3b
Part 1:Sub-clause 10.2.3.3	- Glow-wire test -busbars support material	960 °C
Part 1:Sub-clause 10.3	- Internal degree of protection/ separation	IP2X
	- Verification of degree of protection - External	IP3X and IP4X
Part 1:Sub-clause 10.4	- Verification of clearances and creepage distances	8mm / 16 mm
Part 1:Sub-clause 10.5.2	- Effective earth continuity	< 0.1 Ω
Part 1:Sub-clause 10.9.2	- Power-frequency withstand voltage	2.5 kV , 1 min.
Part 1:Sub-clause 10.9.3	- Impulse voltage withstand test	8 kV
Part 1:Sub-clause 10.10.2.3.5	- Verification of temperature-rise limits-testing with current	2750 A - IP3X
	- Verification of temperature-rise limits-testing with current	2400A - IP4X
Part 1:Sub-clause 10.11.5	- Verification of short-circuit withstand strength	
	- Main and distribution busbars	50kA , 1s
	- Neutral and protective earth (sub-clause 10.5.3.5) busbars	30kA, 1s
	- Functional units-Conditional short-circuit tests	
	- Panels (D2 and D8)	50kA at 400V +10%
	- Panels (A2,B3,B4,B5 and B7))	50kA at 525V +10%
Excluded sub-clauses	- 10.2.2 10.2.3.1 10.2.3.2 10.2.4 10.2.5 10.2.6 10.2.7 10.6 10.7 10.8 10.12 and 10.13	

This report consists of:

Report forms	21	
Data Sheet(s)	13	As appended to this report
Drawing(s)	19	As listed on page 2
Photograph(s)	46	As listed on page 20 and 21
Joint Venture Agreement	3-pages	-As appended to this report
Oscillogram(s)	15	YH3107, YH3108, YI0102 YI0104, YI0105, YI0106 YI0107, YI0108, YI0110 YI0111, YI0112, YI0210 YI0211, YI0212, YI0213


S.S Mnisi

Specialist:Short-Circuit Project.

SABS-NETFA
(Technical Signatory)
J.L Mponyai
Area Manager**SABS-NETFA**

Olifantsfontein, 29 July 2011

Apollo Road, Olifantsfontein. PO Box 144, Olifantsfontein 1665**Tel: +27 (0)11 238 2300, Fax: +27 (0)11 238 2363.**

This test was performed by SABS Commercial (Pty) Ltd. This report and test results relate only to the specific sample(s) identified herein. It does not imply SABS approval of the quality and/or performance of the item (s) in question and the test results do not apply to any similar item that has not been tested. (Refer also to the complete conditions printed on the back of this page)



T0159